

TAMWORTH MONITORING DATA

Licensee:	Downer Edi Works Pty Ltd	Address:	15-27 Armstrong St Tamworth NSW 2340	EPL No.	12118
Sampled:	14/01/15	Obtained:	27/01/15	Published:	12/02/15

Sampling Point	Monitoring frequency as per licence	Pollutant	Result	Discharge Limit	Unit
Outlet Point 2	Discharge after bypass of first flush system.	Suspended Solids	22	50	mg/L
Outlet Point 2	Discharge after bypass of first flush system.	Oil & Grease	<10	10	mg/L

Comment
The water discharge complies with the Environmental Protection Licence.

