

# TAMWORTH MONITORING DATA

<b>Licensee:</b> Downer Edi Works Pty Ltd	<b>Address:</b> 15-27 Armstrong St Tamworth NSW 2340	<b>EPL No.</b> 12118
<b>Sampling Point:</b> Outlet Point 2		<b>Published:</b> January 2021

Stormwater Monitoring Results						
Date Sampled	Report Obtained	Suspended Solids (mg/L)	Suspended Solids Discharge Limit (mg/L)	Oil & Grease (mg/L)	Oil & Grease Discharge Limit (mg/L)	Comments
09/11/2020	13/01/2021	6.7	50	<10	10	Test complies with discharge limits.

